



# PRODUCT PERFORMANCE RATING

Document ID 010420211816-16183097

Issued on 4 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 19.10.171**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Eurovent Heat Pump (Eurovent-HP)
Product type	Variable Refrigerant Flow/ Air cooled/ Reversible
Brand	SAMSUNG
Range	DVM S Eco
Product référence	AM060NXMDGR/EU

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
AMBIENT-SAMSUNG CLIMATE SOLUTIONS	AMBIENT-SAMSUNG CLIMATE SOLUTIONS	SAMSUNG VRF DVM S Eco	Greece

FEATURE	VALUE	UNIT
<b>COOLING</b>		
Pc out	15.50	kW
Pec out	4.13	kW
EERout	3.75	



# PRODUCT PERFORMANCE RATING

Document ID 010420211816-16183097

Issued on 4 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 19.10.171**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING</b>		
Ph out	15.50	kW
Peh out	3.48	kW
COPout	4.45	

FEATURE	VALUE	UNIT
<b>ACOUSTICS</b>		
LwO env	71.00	dB(A)

FEATURE	VALUE	UNIT
<b>SOUND IN HEATING</b>		
LwO env in heating	73.00	dB(A)

FEATURE	VALUE	UNIT
<b>SEASONALCOOLING</b>		
SEER	8.92	
$\eta_{sc}$	353.80	%



# PRODUCT PERFORMANCE RATING

Document ID 010420211816-16183097

Issued on 4 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 19.10.171**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL COND B</b>		
PcB	11.40	kW
EERB	6.70	

FEATURE	VALUE	UNIT
<b>COOLING PL COND C</b>		
PcC	7.30	kW
EERC	11.70	

FEATURE	VALUE	UNIT
<b>COOLING PL COND D</b>		
PcD	4.40	kW
EERD	15.50	



# PRODUCT PERFORMANCE RATING

Document ID 010420211816-16183097

Issued on 4 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 19.10.171**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>SEASONAL HEATING</b>		
Pdesignh	10.40	kW
SCOP	4.65	
$\eta_{sh}$	183.00	%

FEATURE	VALUE	UNIT
<b>HEATING PL COND A</b>		
PhA	9.20	kW
COPA	2.50	

FEATURE	VALUE	UNIT
<b>HEATING PL COND B</b>		
PhB	5.60	kW
COPB	4.70	



# PRODUCT PERFORMANCE RATING

Document ID 010420211816-16183097

Issued on 4 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 19.10.171**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL COND C</b>		
PhC	3.60	kW
COPC	6.30	

FEATURE	VALUE	UNIT
<b>HEATING PL COND D</b>		
PhD	2.90	kW
COPD	8.40	

FEATURE	VALUE	UNIT
<b>T BIVALENT</b>		
Tbiv	-10.00	°C
PhTbiv	10.40	kW
COPTbiv	2.20	

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psbc	22.00	W



# PRODUCT PERFORMANCE RATING

Document ID 010420211816-16183097

Issued on 4 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 19.10.171**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>PSBH</b>		
Psbh	22.00	W

FEATURE	VALUE	UNIT
<b>GENERAL - PRODUCT</b>		
Main Power Supply	400-3-50	
Refrigerant	R410A	
Mounting	Cassette	
Cassette Type	4-way	
IU Names	AM040NN4FEH	
IU Range Names	Wind Free High Efficiency	
Capacity Control	Variable	